



# EPTAMETIC BITZER R452A

## ENERGY EFFICIENCY DATA SHEETS

*Values of COP and SEPR in conformity  
to the rule UE2015/1095 of May 5<sup>th</sup> 2015*

Nº DOC. Im000103  
REV. “-” - 04.04.17

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	2/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model	EPTAMETIC- GN18 BITZER
Refrigerating Fluid	R452a

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	x	

Parameters at full load and at a room temperature of 32°C (Point A)			
Nominal cooling capacity	$P_A$	1,22	kW
Nominal absorbed power	$D_A$	1,19	kW
Declared COP	$COP_A$	1,02	

Parameters at full load and at a room temperature of 25°C (Point B)			
Nominal cooling capacity	$P_B$	1,48	kW
Nominal absorbed power	$D_B$	1,20	kW
Declared COP	$COP_B$	1,23	

Parameters at full load and at a room temperature of 15°C (Point C)			
Nominal cooling capacity	$P_C$	x	kW
Nominal absorbed power	$D_C$	x	kW
Declared COP	$COP_C$	x	

Parameters at full load and at a room temperature of 5°C (Point D)			
Nominal cooling capacity	$P_D$	x	kW
Nominal absorbed power	$D_D$	x	kW
Declared COP	$COP_D$	x	

Parameters at full load and at a room temperature of 43°C			
Nominal cooling capacity	$P_3$	0,85	kW
Nominal absorbed power	$D_3$	1,20	kW
Declared COP	$COP_3$	0,71	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	3/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN28 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,59	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	1,74	kW
Nominal absorbed power	$D_A$	1,60	kW
Nominal COP	$COP_A$	1,09	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	2,07	kW
Nominal absorbed power	$D_B$	1,56	kW
Declared COP	$COP_B$	1,33	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	2,55	kW
Nominal absorbed power	$D_C$	1,49	kW
Declared COP	$COP_C$	1,71	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	3,00	kW
Nominal absorbed power	$D_D$	1,44	kW
Declared COP	$COP_D$	2,09	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	1,22	kW
Nominal absorbed power	$D_3$	1,56	kW
Declared COP	$COP_3$	0,78	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	4/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model	EPTAMETIC- GN40 BITZER
Refrigerating Fluid	R452a

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,82	

Parameters at full load and at a room temperature of 32°C (Point A)			
Nominal cooling capacity	$P_A$	2,23	kW
Nominal absorbed power	$D_A$	1,97	kW
Declared COP	$COP_A$	1,13	

Parameters at full load and at a room temperature of 25°C (Point B)			
Nominal cooling capacity	$P_B$	2,63	kW
Nominal absorbed power	$D_B$	1,93	kW
Declared COP	$COP_B$	1,36	

Parameters at full load and at a room temperature of 15°C (Point C)			
Nominal cooling capacity	$P_C$	3,19	kW
Nominal absorbed power	$D_C$	1,85	kW
Declared COP	$COP_C$	1,72	

Parameters at full load and at a room temperature of 5°C (Point D)			
Nominal cooling capacity	$P_D$	3,72	kW
Nominal absorbed power	$D_D$	1,76	kW
Declared COP	$COP_D$	2,11	

Parameters at full load and at a room temperature of 43°C			
Nominal cooling capacity	$P_3$	1,61	kW
Nominal absorbed power	$D_3$	1,98	kW
Declared COP	$COP_3$	0,81	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	5/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN41 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,57	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	2,46	kW
Nominal absorbed power	$D_A$	2,24	kW
Nominal COP	$COP_A$	1,10	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	2,85	kW
Nominal absorbed power	$D_B$	2,17	kW
Declared COP	$COP_B$	1,31	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	3,38	kW
Nominal absorbed power	$D_C$	2,04	kW
Declared COP	$COP_C$	1,66	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	3,90	kW
Nominal absorbed power	$D_D$	1,90	kW
Declared COP	$COP_D$	2,05	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	1,85	kW
Nominal absorbed power	$D_3$	2,23	kW
Declared COP	$COP_3$	0,83	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	6/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN50 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,61	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	3,24	kW
Nominal absorbed power	$D_A$	2,79	kW
Nominal COP	$COP_A$	1,16	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	3,75	kW
Nominal absorbed power	$D_B$	2,72	kW
Declared COP	$COP_B$	1,38	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	4,48	kW
Nominal absorbed power	$D_C$	2,60	kW
Declared COP	$COP_C$	1,72	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	5,12	kW
Nominal absorbed power	$D_D$	2,47	kW
Declared COP	$COP_D$	2,07	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	2,45	kW
Nominal absorbed power	$D_3$	2,85	kW
Declared COP	$COP_3$	0,86	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	7/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN70 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
<b>Evaporation temperature</b>	<i>t</i>	-35°C	°C
<b>Annual consumption of electrical energy</b>	<i>Q</i>	x	kWh/a
<b>Seasonal energy efficiency ratio</b>	<i>SEPR</i>	1,46	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	<i>P<sub>A</sub></i>	3,75	kW
Nominal absorbed power	<i>D<sub>A</sub></i>	3,68	kW
Nominal COP	<i>COP<sub>A</sub></i>	1,02	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	<i>P<sub>B</sub></i>	4,39	kW
Nominal absorbed power	<i>D<sub>B</sub></i>	3,60	kW
Declared COP	<i>COP<sub>B</sub></i>	1,22	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	<i>P<sub>C</sub></i>	5,30	kW
Nominal absorbed power	<i>D<sub>C</sub></i>	3,42	kW
Declared COP	<i>COP<sub>C</sub></i>	1,55	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	<i>P<sub>D</sub></i>	6,18	kW
Nominal absorbed power	<i>D<sub>A</sub></i>	3,20	kW
Declared COP	<i>COP<sub>D</sub></i>	1,93	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	<i>P<sub>3</sub></i>	2,79	kW
Nominal absorbed power	<i>D<sub>3</sub></i>	3,72	kW
Declared COP	<i>COP<sub>3</sub></i>	0,75	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	<i>Cdc</i>		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	8/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN75 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
<b>Evaporation temperature</b>	<i>t</i>	-35°C	°C
<b>Annual consumption of electrical energy</b>	<i>Q</i>	x	kWh/a
<b>Seasonal energy efficiency ratio</b>	<i>SEPR</i>	1,52	

#### Parameters at full load and at a room temperature of 32°C

(Point A)

Nominal cooling capacity	<i>P<sub>A</sub></i>	4,08	kW
Nominal absorbed power	<i>D<sub>A</sub></i>	3,67	kW
Nominal COP	<i>COP<sub>A</sub></i>	1,11	

#### Parameters at full load and at a room temperature of 25°C

(Point B)

Nominal cooling capacity	<i>P<sub>B</sub></i>	4,94	kW
Nominal absorbed power	<i>D<sub>B</sub></i>	3,72	kW
Declared COP	<i>COP<sub>B</sub></i>	1,33	

#### Parameters at full load and at a room temperature of 15°C

(Point C)

Nominal cooling capacity	<i>P<sub>C</sub></i>	6,23	kW
Nominal absorbed power	<i>D<sub>C</sub></i>	3,80	kW
Declared COP	<i>COP<sub>C</sub></i>	1,64	

#### Parameters at full load and at a room temperature of 5°C

(Point D)

Nominal cooling capacity	<i>P<sub>D</sub></i>	7,56	kW
Nominal absorbed power	<i>D<sub>A</sub></i>	3,82	kW
Declared COP	<i>COP<sub>D</sub></i>	1,98	

#### Parameters at full load and at a room temperature of 43°C

Nominal cooling capacity	<i>P<sub>3</sub></i>	2,84	kW
Nominal absorbed power	<i>D<sub>3</sub></i>	3,64	kW
Declared COP	<i>COP<sub>3</sub></i>	0,78	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	<i>Cdc</i>	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	9/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN76 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,61	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	5,34	kW
Nominal absorbed power	$D_A$	4,57	kW
Nominal COP	$COP_A$	1,17	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	6,37	kW
Nominal absorbed power	$D_B$	4,58	kW
Declared COP	$COP_B$	1,39	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	7,88	kW
Nominal absorbed power	$D_C$	4,56	kW
Declared COP	$COP_C$	1,73	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	9,41	kW
Nominal absorbed power	$D_D$	4,46	kW
Declared COP	$COP_D$	2,11	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	3,83	kW
Nominal absorbed power	$D_3$	4,56	kW
Declared COP	$COP_3$	0,84	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	10/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN100 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,51	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	5,97	kW
Nominal absorbed power	$D_A$	5,58	kW
Nominal COP	$COP_A$	1,07	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	7,19	kW
Nominal absorbed power	$D_B$	5,62	kW
Declared COP	$COP_B$	1,28	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	9,01	kW
Nominal absorbed power	$D_C$	5,56	kW
Declared COP	$COP_C$	1,62	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	10,85	kW
Nominal absorbed power	$D_D$	5,43	kW
Declared COP	$COP_D$	2,00	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	4,17	kW
Nominal absorbed power	$D_3$	5,35	kW
Declared COP	$COP_3$	0,78	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	11/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN150 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,47	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	10,25	kW
Nominal absorbed power	$D_A$	9,85	kW
Nominal COP	$COP_A$	1,04	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	12,09	kW
Nominal absorbed power	$D_B$	9,67	kW
Declared COP	$COP_B$	1,25	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	14,72	kW
Nominal absorbed power	$D_C$	9,32	kW
Declared COP	$COP_C$	1,58	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	17,06	kW
Nominal absorbed power	$D_D$	8,93	kW
Declared COP	$COP_D$	1,91	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	7,51	kW
Nominal absorbed power	$D_3$	9,88	kW
Declared COP	$COP_3$	0,76	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	12/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN200 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,54	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	7,31	kW
Nominal absorbed power	$D_A$	6,77	kW
Nominal COP	$COP_A$	1,08	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	8,71	kW
Nominal absorbed power	$D_B$	6,75	kW
Declared COP	$COP_B$	1,29	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	10,71	kW
Nominal absorbed power	$D_C$	6,53	kW
Declared COP	$COP_C$	1,64	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	12,67	kW
Nominal absorbed power	$D_D$	6,21	kW
Declared COP	$COP_D$	2,04	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	5,23	kW
Nominal absorbed power	$D_3$	6,54	kW
Declared COP	$COP_3$	0,80	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	13/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GN300 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-35°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	1,52	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	12,17	kW
Nominal absorbed power	$D_A$	11,37	kW
Nominal COP	$COP_A$	1,07	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	14,23	kW
Nominal absorbed power	$D_B$	11,11	kW
Declared COP	$COP_B$	1,28	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	17,15	kW
Nominal absorbed power	$D_C$	10,65	kW
Declared COP	$COP_C$	1,61	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	19,91	kW
Nominal absorbed power	$D_D$	10,06	kW
Declared COP	$COP_D$	1,98	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	9,11	kW
Nominal absorbed power	$D_3$	11,53	kW
Declared COP	$COP_3$	0,79	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	14/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP05 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	x	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	1,85	kW
Nominal absorbed power	$D_A$	0,92	kW
Nominal COP	$COP_A$	2,01	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	2,08	kW
Nominal absorbed power	$D_B$	0,89	kW
Declared COP	$COP_B$	2,35	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	x	kW
Nominal absorbed power	$D_C$	x	kW
Declared COP	$COP_C$	x	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	x	kW
Nominal absorbed power	$D_D$	x	kW
Declared COP	$COP_D$	x	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	1,47	kW
Nominal absorbed power	$D_3$	0,95	kW
Declared COP	$COP_3$	1,55	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	15/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP10 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	x	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	2,36	kW
Nominal absorbed power	$D_A$	1,27	kW
Nominal COP	$COP_A$	1,86	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	2,70	kW
Nominal absorbed power	$D_B$	1,20	kW
Declared COP	$COP_B$	2,26	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	x	kW
Nominal absorbed power	$D_C$	x	kW
Declared COP	$COP_C$	x	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	x	kW
Nominal absorbed power	$D_D$	x	kW
Declared COP	$COP_D$	x	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	1,84	kW
Nominal absorbed power	$D_3$	1,35	kW
Declared COP	$COP_3$	1,37	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	16/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP15 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	x	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	2,92	kW
Nominal absorbed power	$D_A$	1,61	kW
Nominal COP	$COP_A$	1,81	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	3,34	kW
Nominal absorbed power	$D_B$	1,53	kW
Declared COP	$COP_B$	2,18	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	x	kW
Nominal absorbed power	$D_C$	x	kW
Declared COP	$COP_C$	x	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	x	kW
Nominal absorbed power	$D_D$	x	kW
Declared COP	$COP_D$	x	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	2,28	kW
Nominal absorbed power	$D_3$	1,71	kW
Declared COP	$COP_3$	1,33	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	17/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP20 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	x	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	4,26	kW
Nominal absorbed power	$D_A$	2,29	kW
Nominal COP	$COP_A$	1,86	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	4,87	kW
Nominal absorbed power	$D_B$	2,17	kW
Declared COP	$COP_B$	2,24	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	x	kW
Nominal absorbed power	$D_C$	x	kW
Declared COP	$COP_C$	x	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	x	kW
Nominal absorbed power	$D_D$	x	kW
Declared COP	$COP_D$	x	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	3,34	kW
Nominal absorbed power	$D_3$	2,45	kW
Declared COP	$COP_3$	1,36	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	18/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP25 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	2,85	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	5,20	kW
Nominal absorbed power	$D_A$	2,60	kW
Nominal COP	$COP_A$	2,00	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	5,91	kW
Nominal absorbed power	$D_B$	2,48	kW
Declared COP	$COP_B$	2,38	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	6,90	kW
Nominal absorbed power	$D_C$	2,26	kW
Declared COP	$COP_C$	3,05	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	7,84	kW
Nominal absorbed power	$D_D$	1,97	kW
Declared COP	$COP_D$	3,98	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	4,06	kW
Nominal absorbed power	$D_3$	2,73	kW
Declared COP	$COP_3$	1,49	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	19/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP30 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	2,66	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	7,49	kW
Nominal absorbed power	$D_A$	4,00	kW
Nominal COP	$COP_A$	1,87	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	8,48	kW
Nominal absorbed power	$D_B$	3,80	kW
Declared COP	$COP_B$	2,23	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	9,86	kW
Nominal absorbed power	$D_C$	3,46	kW
Declared COP	$COP_C$	2,85	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	11,17	kW
Nominal absorbed power	$D_D$	3,01	kW
Declared COP	$COP_D$	3,71	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	5,90	kW
Nominal absorbed power	$D_3$	4,18	kW
Declared COP	$COP_3$	1,41	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	20/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP40 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	2,93	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	8,42	kW
Nominal absorbed power	$D_A$	4,21	kW
Nominal COP	$COP_A$	2,00	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	9,51	kW
Nominal absorbed power	$D_B$	3,98	kW
Declared COP	$COP_B$	2,39	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	11,02	kW
Nominal absorbed power	$D_C$	3,54	kW
Declared COP	$COP_C$	3,11	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	12,44	kW
Nominal absorbed power	$D_D$	2,98	kW
Declared COP	$COP_D$	4,17	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	6,66	kW
Nominal absorbed power	$D_3$	4,38	kW
Declared COP	$COP_3$	1,52	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	21/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP47 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	2,85	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	11,05	kW
Nominal absorbed power	$D_A$	5,61	kW
Nominal COP	$COP_A$	1,97	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	12,45	kW
Nominal absorbed power	$D_B$	5,30	kW
Declared COP	$COP_B$	2,35	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	14,36	kW
Nominal absorbed power	$D_C$	4,72	kW
Declared COP	$COP_C$	3,04	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	16,17	kW
Nominal absorbed power	$D_D$	4,03	kW
Declared COP	$COP_D$	4,01	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	8,81	kW
Nominal absorbed power	$D_3$	5,99	kW
Declared COP	$COP_3$	1,47	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	22/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP50 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	3,15	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	13,16	kW
Nominal absorbed power	$D_A$	6,09	kW
Nominal COP	$COP_A$	2,16	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	14,82	kW
Nominal absorbed power	$D_B$	5,70	kW
Declared COP	$COP_B$	2,60	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	17,14	kW
Nominal absorbed power	$D_C$	5,07	kW
Declared COP	$COP_C$	3,38	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	17,14	kW
Nominal absorbed power	$D_D$	3,91	kW
Declared COP	$COP_D$	4,38	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	10,53	kW
Nominal absorbed power	$D_3$	6,58	kW
Declared COP	$COP_3$	1,60	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$	0,25	

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	23/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP75 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	2,85	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	15,65	kW
Nominal absorbed power	$D_A$	7,67	kW
Nominal COP	$COP_A$	2,04	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	17,79	kW
Nominal absorbed power	$D_B$	7,35	kW
Declared COP	$COP_B$	2,42	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	20,97	kW
Nominal absorbed power	$D_C$	6,81	kW
Declared COP	$COP_C$	3,08	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	24,24	kW
Nominal absorbed power	$D_D$	6,15	kW
Declared COP	$COP_D$	3,94	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	12,40	kW
Nominal absorbed power	$D_3$	8,21	kW
Declared COP	$COP_3$	1,51	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	24/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP100 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	2,81	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	19,67	kW
Nominal absorbed power	$D_A$	9,88	kW
Nominal COP	$COP_A$	1,99	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	22,28	kW
Nominal absorbed power	$D_B$	9,40	kW
Declared COP	$COP_B$	2,37	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	26,07	kW
Nominal absorbed power	$D_C$	8,63	kW
Declared COP	$COP_C$	3,02	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	29,86	kW
Nominal absorbed power	$D_D$	7,68	kW
Declared COP	$COP_D$	3,89	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	15,66	kW
Nominal absorbed power	$D_3$	10,51	kW
Declared COP	$COP_3$	1,49	
Control of capacity	fixed		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	25/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP150 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	3,33	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	23,76	kW
Nominal absorbed power	$D_A$	11,15	kW
Nominal COP	$COP_A$	2,13	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	26,98	kW
Nominal absorbed power	$D_B$	10,62	kW
Declared COP	$COP_B$	2,54	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	31,53	kW
Nominal absorbed power	$D_C$	9,64	kW
Declared COP	$COP_C$	3,27	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	35,97	kW
Nominal absorbed power	$D_D$	8,50	kW
Declared COP	$COP_D$	4,23	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	18,72	kW
Nominal absorbed power	$D_3$	11,85	kW
Declared COP	$COP_3$	1,58	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		

TECHNICAL DOCUMENTATION		STATE REVISION OF THE CHAPTER				IN CONFORMITY WHITH THE APPROVED ORIGINAL	Epta	
PRODUCT	EPTAMET.BIT.R452A	ORD.	DATE	ORD.	DATE		PAGE	26/27
N° DOC.	IM000103	A		D			FIRST ISSUE	04.04.17
N° CHAP.		B		E			ISSUE	MKTG
		C		F				

Model

**EPTAMETIC- GP200 BITZER**

Refrigerating Fluid

**R452a**

Element	Symbol	Value	Unit
Evaporation temperature	t	-10°C	°C
Annual consumption of electrical energy	Q	x	kWh/a
Seasonal energy efficiency ratio	SEPR	3,00	

**Parameters at full load and at a room temperature of 32°C  
(Point A)**

Nominal cooling capacity	$P_A$	27,76	kW
Nominal absorbed power	$D_A$	13,35	kW
Nominal COP	$COP_A$	2,08	

**Parameters at full load and at a room temperature of 25°C  
(Point B)**

Nominal cooling capacity	$P_B$	31,37	kW
Nominal absorbed power	$D_B$	12,60	kW
Declared COP	$COP_B$	2,49	

**Parameters at full load and at a room temperature of 15°C  
(Point C)**

Nominal cooling capacity	$P_C$	36,36	kW
Nominal absorbed power	$D_C$	11,33	kW
Declared COP	$COP_C$	3,21	

**Parameters at full load and at a room temperature of 5°C  
(Point D)**

Nominal cooling capacity	$P_D$	41,01	kW
Nominal absorbed power	$D_D$	9,81	kW
Declared COP	$COP_D$	4,18	

**Parameters at full load and at a room temperature of 43°C**

Nominal cooling capacity	$P_3$	22,01	kW
Nominal absorbed power	$D_3$	14,20	kW
Declared COP	$COP_3$	1,55	
Control of capacity	<i>fixed</i>		
Degradation coefficient of the units with a fixed and progressive capacity	$Cdc$		
	0,25		



EN ISO 9001  
20 100 52000-877  
EN 13430  
20 104 441373322  
OHSAS 18001  
20 116 141373323